

RESOLUTION NO. 103-94

April 7, 1994

**A RESOLUTION OF THE BOARD OF DIRECTORS OF THE
VANDENBERG VILLAGE COMMUNITY SERVICES DISTRICT
FINDING OF CATEGORICAL EXEMPTION FOR
CHEMICAL DISINFECTION PROJECT**

WHEREAS, Vandenberg Village Community Services District has decided to replace its existing gaseous chlorine facilities with liquid sodium hypochlorite and its existing gaseous sulfur dioxide with liquid sodium bisulfite in order to relieve the District from the burdens of highly regulated acutely hazardous materials; and

WHEREAS, the proposed project is a minor alteration of existing public facilities involving no expansion of use beyond that previously existing; and

WHEREAS, this Board has reviewed the proposed project description which is attached hereto as Exhibit A.

NOW THEREFORE, BE IT RESOLVED by the Board of Directors of the Vandenberg Village Community Services District that the proposed project to replace existing gaseous disinfection chemicals with liquid disinfection chemicals meets the criteria under Section 15301 of the California Environmental Quality Act Guidelines for Class I - CATEGORICAL EXEMPTION; and

BE IT FURTHER RESOLVED that this Board hereby finds, determines, and declares the proposed project to be CATEGORICALLY EXEMPT from CEQA and the staff is directed to file Notice of Exemption upon project approval in accordance with Section 15062 of the CEQA Guidelines.

On the motion of Director Small

Second Director Nosler

Roll call vote, to wit:

AYES: Directors Nash, Nosler, Picciuolo, and Small
NOES: None
ABSENT: Director White
ABSTAIN: None

Resolution No. 103-94 is hereby adopted.

Jon C. Picciuolo
Vice President, Board of Directors

ATTEST:

Gwen Jerep, Secretary
Board of Directors

SECRETARY'S CERTIFICATE

I, Gwen Jerep, Secretary of the Board of Directors of the Vandenberg Village Community Services District, hereby certify that the foregoing is a true and correct copy of Resolution No. 103-94, passed and adopted by the Board of Directors of the Vandenberg Village Community Services District at its Regular Meeting held on the 7th day of April, 1994.

Gwen Jerep

Resolution No. 103-94
April 7, 1994

EXHIBIT A

PROJECT DESCRIPTION

REPLACE GASEOUS DISINFECTION FACILITIES WITH LIQUID DISINFECTION FACILITIES

Install 3000 gallon cross-linked HDPE storage tank with secondary containment tank for storage of sodium hypochlorite and install 700 gallon cross-linked HDPE storage tank with secondary containment tank for storage of sodium bisulfite. Install pumps, conduit, and controls for the injection of stored chemicals into existing water treatment plant. Tanks are to be located adjacent to existing chemical storage facilities in an area now paved with asphalt. Pumps, controls and appurtenances are to be located within existing sulfur dioxide storage room at the existing treatment plant. All proposed facilities are to be located within the existing paved area or existing buildings at VVCSD Site #1 treatment plant. Plumbing for injection of chemicals to utilize existing conduits and/or piping from the existing sulfur dioxide room to injection points at reactor vessels.